



DEPARTMENT OF HEALTH & HUMAN SERVICES

d1542b 4/8/98  
Public Health Service  
Food and Drug Administration

Dallas District  
3310 Live Oak Street  
Dallas, Texas 75204-6131

March 30, 1998

Ref: 98-DAL-WL-30

**WARNING LETTER**

**CERTIFIED MAIL**  
**RETURN RECEIPT REQUESTED**

Mr. Charles Koch  
President  
Koch Ingleside Terminal  
4111 East 37th Street North  
Wichita, Kansas 67220

Dear Mr. Koch:

During an inspection of the Koch Ingleside Terminal, vessel watering point, Ingleside, Texas, on March 11, 1998, our investigator documented deviations from Title 21, Code of Federal Regulations (CFR), Part 1250. Therefore, the referenced vessel watering point has been classified as "Provisional."

Our investigation revealed significant insanitary conditions, including:

1. A backflow prevention device was not provided for a water line attached to the potable water outlet.
2. The cap was not present on potable water outlet.
3. Potable and non-potable water outlets were on the same dock and not properly identified.

This letter is not intended to be an all-inclusive list of deficiencies at your vessel watering point and it is your responsibility to ensure adherence to each requirement of the regulations. You should assure that all vessel watering points under your control are in compliance with the regulations.

A list of Inspectional Observations (FDA-483) was issued to and discussed with you. A copy of the FDA-483 is enclosed for your reference. Please review the observations noted by the investigator at the Ingleside, Texas, location inspected. You should take prompt action to correct these deviations and ensure that future violations do not recur. Failure to

Page 2- Mr. Charles Koch  
March 30, 1998

correct these critical violations can result in further action by FDA. Your vessel watering point may be placed on a "Not Approved" status if future similar violations occur.

You should notify this office in writing, within fifteen (15) days of receipt of this letter, stating the specific steps you have taken to correct the aforementioned violations. Your reply should be directed to Gwen Gilbreath, Compliance Officer, at the above letterhead address.

Sincerely,



Joe Joseph R. Baca  
Dallas District Director

Attachment- FDA-483

JRB:GSG

cc: Mr. Calvin Stout  
Foreman  
Koch Ingleside Terminal  
End of FM 1069  
Ingleside, Texas 78362

Mr. James R. Mawer  
Operations Manager