



DEPARTMENT OF HEALTH & HUMAN SERVICES

Public Health Service
Food and Drug Administration

Q 3062d
San Francisco District
1431 Harbor Bay Parkway
Alameda, CA 94502-7070
Telephone: 510/337-6700

WARNING LETTER

VIA FEDERAL EXPRESS

January 25, 2002

Our Reference Number: FEI3003383303

Nancy J. Soy, Board of Directors Chairperson
Monterey Peninsula Airport District
200 Fred Kane Drive, Suite 200 4165 0463 2115
Monterey, CA 93940

Dear Ms. Soy,

On January 9, 2002, FDA Investigator Lorna Jones conducted an inspection of your facility located at Monterey Peninsula Airport, Monterey, CA, which provides waste service to all airlines utilizing the Monterey Peninsula Airport. Your operations at this site are in serious violation of Interstate Conveyance Sanitation regulations which are established in Title 21, Code of Federal Regulations, Part 1250 (21 CFR 1250). Investigator Jones' observations were listed on Form FDA 483, List of Inspectional Observations, a copy of which was provided to, and discussed with, Ms. Jacqueline Hulse, Chief of Operations & Maintenance/Operations Manager, at the conclusion of the inspection.


Investigator Jones' observations include the following: The airport's waste service area continues to dump aircraft sewage into a manhole, which is not a properly constructed sewage disposal facility. Water is not available for tenants to use during dumping of aircraft sewage. The deficiencies found at your facility could contribute to the spread of communicable diseases, in consequence of which your operation has been assigned a "Provisional" classification. If the deficiencies are not corrected within thirty (30) days from the receipt of this notification, your facility will be placed on "Not Approved" status. Assignment of "Not Approved" status prohibits the use of your waste disposal services for interstate conveyances until the violations have been corrected and the facility has been reinspected by FDA.

You should notify this office within fifteen (15) working days of the receipt of this letter of the specific steps that you have taken to prevent a recurrence of the cited deficiencies. Your response should be directed to:

Warren E. Savary, Compliance Officer
U.S. Food and Drug Administration
1431 Harbor Bay Parkway
Alameda, CA 94502

You may wish to FAX your response to Mr. Savary at (510) 337-6707.

Sincerely,

A handwritten signature in black ink, appearing to read "Dennis Linsley". The signature is fluid and cursive, written over a white background.

Dennis Linsley
Director
San Francisco District

Cc: Denis R. Horn, General Manager
Jacqueline Hulsey, Chief of Operations & Maintenance/Operations Manager

Enclosures:

Form FDA 2528, "Inspection Summary - Airline Service Area or Watering Point Sanitation," dated 1/09/02.

FDA 483, Inspectional Observations, dated 1/09/02.