

DEPARTMENT OF HEALTH & HUMAN SERVICES

Public Health Service  
Food and Drug Administration

HFI-35  
7/8/97  
612

Refer to: CFN 1130592

Baltimore District  
900 Madison Avenue  
Baltimore, Maryland 21201  
Telephone: (410) 962-4012

July 3, 1997

**WARNING LETTER**

**CERTIFIED MAIL**  
**RETURN RECEIPT REQUESTED**

Mr. Robert Quick, President  
Quick-Livick, Incorporated  
708 "C" Street  
Staunton, Virginia 24401

Dear Mr. Quick:

An inspection was conducted on June 23, 1997, of your D & B Bus Division facility in Falmouth, Virginia. This inspection was conducted under the authority of the Public Health Service Act and the Federal Food, Drug, and Cosmetic Act.

The List of Observations (FDA-483) was issued to and discussed with Mr. Ralph Ackers, Shop Foreman. A copy of the FDA-483 is enclosed for your reference.

The inspection revealed a significant deviation from the Interstate Conveyance Regulations [21 CFR 1250], as follows:

- 1) Lack of back flow preventer on the hose used to fill bus toilets and to flush the sewage dumping pit.

As a result of this inspectional finding, this facility has been classified as "Provisional." A reinspection will be conducted on or about July 23, 1997, to determine if your future classification will be "Approved" or "Not Approved." A "Not Approved" classification means you cannot provide water/sewage service to passenger buses.

Mr. Robert Quick  
Page 2  
July 3, 1997

Please advise this office in writing within 15 days of receipt of this letter regarding actions taken to correct the deficiency and to assure that such violative conditions will not recur. Your response should be directed to Wiley T. Williamson, III, Compliance Officer.

Sincerely,



Elaine Knowles Cole  
Baltimore District Director

Enclosure