

Variance Attachment A
Variance No. 99V-0555
COKA (Cook Arts, Science & Technology Center)

1. This variance is not transferable to any other firm or person and applies only to the specific products identified in the variance.
2. All laser products, systems, shows, and projectors shall be certified to comply with applicable requirements of 21 CFR 1040.10 and the conditions of this variance and be reported as required by 21 CFR 1002.10 and 1002.12 using the reporting guides provided for such purpose. These actions shall be accomplished prior to any introduction into commerce.
3. Effects not specifically indicated in this variance approval shall not be performed. Any additional effects require the submission of an amendment request (using Form 3147 or in accordance with 21 CFR 1010.4) and the filing of product reports or supplements as applicable.
4. Laser projection systems and light shows manufactured, assembled, or produced under this variance shall not be transferred to any other party until the recipient has demonstrated that they have a variance, as required, in effect that permits them to produce certified laser light shows incorporating these laser projection systems. A notation of the recipient's variance number and its effective date, as applicable, shall be entered and retained in the records of compliance test results required by 21 CFR 1002.30.
5. Scanning, projection, or reflection of laser and collateral radiation (light show radiation) into audience or other accessible uncontrolled areas shall not be permitted except for diffuse reflections produced by the atmosphere, added atmospheric scattering media, and target screens.
6. Access to radiation levels in excess of the limits of Class I by any person other than operators, performers, or employees shall not be permitted at any point less than 3.0 meters above any surface upon which such persons are permitted to stand or 2.5 meters below or in lateral separation from any place where such persons are permitted to be. Operators, performers, and employees shall not be required or allowed to view radiation above the limits of Class I or be exposed to radiation above the limits of Class II.

7. Any product which relies on scanning to meet access, exposure, or product class limits shall incorporate a scanning safeguard system which directly senses scanner motion and which will react fast enough to preclude exceeding the applicable limit.
8. All laser light shows shall be under the direct and personal control of a trained, competent operator(s). The operator(s) shall:
 - (a) be an employee of the variance holder who shall be responsible for the training and conduct of the operator;
 - (b) be located where all beam paths can be directly observed at all times; and
 - (c) immediately terminate the emission of light show radiation in the event of any unsafe condition and, for open air shows, at the request of any air traffic control officials.
9. The maximum laser projector output power shall not exceed the level required to obtain the intended effects.
10. The projection system (i.e., the projector and all other components used to produce the lighting effects) shall be securely mounted or immobilized to prevent unintended movement or misalignment.

Electronic controls and circuits shall be adequately shielded to prevent electromagnetic sources (e.g., walkie-talkies, head-set radios, wireless microphones, cellular telephones, etc.) in the vicinity of the projector, its active projection heads, and control system(s) from causing the laser emissions to be misdirected from their intended target area.

Beam masking to prevent projections into prohibited areas or directions or overfilling of screens, beam stops, targets, etc. shall be incorporated as an inherent part of the system design. Such devices may be adjustable if the system's intended use environment requires such capability.
11. In addition to the requirements of 21 CFR 1040.10(h), the manufacturer of laser projectors/systems shall provide to parties who purchase, lease, or borrow the equipment, adequate user's instructions for safe installation and operation. These instructions shall also explain the responsibility of the recipient as an independent light show manufacturer to submit the required reports and apply for and obtain a variance from the Center for Devices and Radiological Health (CDRH) prior to the introduction into commerce of any laser light shows.

12. The requirements of 21 CFR 1002.30(a) (1) and (2) shall be accomplished through the use of written procedures for setup, alignment, testing, and performance of each show. These procedures shall be in sufficient detail to ensure compliance with 21 CFR 1040.10, the conditions of this variance, and any emergency shutdown requirements, and the control of access to radiation areas using the procedures described in the ANSI Z136.1-1993 Standard For The Safe Use of Lasers (available from The Laser Institute of America, 1242 Research Parkway, Suite 130, Orlando, Florida 32826) or any other equivalent user consensus standard and, where applicable, State or local requirements.

Laser radiation areas which can contain radiation levels above Class I or II as applicable, shall be clearly identified by the posting of warning signs and/or restricting access through physical means (such as pressure switches, photocells, barriers, guards, etc.). These requirements apply to temporary areas (such as during setup and alignment procedures) and to final or permanent areas.

The variance holder shall retain the records of these procedures and the results of all tests as required by 21 CFR 1002.31. A copy of the variance application, the approval letter, current procedures, and records relating to each particular show shall be with the operator or other responsible individual and shall be made available for inspection by FDA and other responsible authorities.

13. Advance written notification shall be made as early as possible to appropriate Federal, State, and local authorities providing show itinerary with dates and locations clearly and completely identified, and a basic description of proposed effects including a statement of the maximum power output intended. Such notifications shall be made, but not necessarily be limited, to:
 - (a) The Center for Devices and Radiological Health (CDRH), Office of Communication, Education, and Radiation Programs (address below) and the Electro Optic Specialist responsible for the location of the show (addresses below) providing the initial and closing dates for fixed installations and the itinerary for mobile shows. In addition, unless all aspects of each show have been reported and the Accession Number(s) clearly referenced, each notice shall include detailed descriptions of each show and a listing of all effects to be performed in sufficient detail to confirm compliance with the regulations and this variance. To be considered timely, this written notice must be submitted 30 days prior to the opening of the subject show or, when the show becomes known to the manufacturer less than 30 days prior to the show date, the required information must be provided verbally in an immediate phone call to CDRH and also confirmed in the formal written notice that includes the date of the phone notification and the name of the official to whom the information was given.

- (b) The Federal Aviation Administration (FAA) and the Department of Defense (DOD) for any projections into open airspace at any time (i.e., including setup, alignment, rehearsals, performances, etc.). If the FAA or DOD objects to any laser effects, the objections shall be resolved and any conditions requested by FAA and DOD will be adhered to. If these conditions can not be met, the objectionable effects shall be deleted from the show.
- (c) State and local radiation control offices/agencies for all shows to be performed within their jurisdictions. All requirements of State and local law shall be satisfied and any objections raised by local authorities shall be resolved or the effects deleted.

Unless otherwise specified by regulation (e.g., variance applications), all correspondence to be provided to the CDRH shall be addressed to:

Center for Devices and Radiological Health
Electronic Products Branch (HFZ-342)
Office of Communications, Education, and
Radiation Programs
2098 Gaither Road
Rockville, MD 20850
Phone: Voice: (240) 276-0120
FAX: (240) 276-0129

REGIONAL ELECTRO-OPTICS SPECIALISTS

09/02/2004

For States: ME, NH, VT, MA, NY, CT, RI

Captain Max Lager, EOS
FDA (HFR-NE25)
1 Montvale Avenue
Stoneham, MA 02180-3542

781-279-1675 x1754
781-279-1687 (fax)

mlager@ora.fda.gov

For States: TN, NC, SC, GA, FL, PR, AL, MS, LA

Leo J. Lagrotte, EOS
FDA (HFR-SE2585)
3350 Buschwood Park Drive, Room 170
Tampa, FL 33618

813-228-2671 x35
813-228-2046 (fax)

leo.lagrotte@fda.hhs.gov

For States: NJ, DE, MD, DC, VA, PA, WV, KY, OH, IN, IL, MI, WI, MN, ND, SD

James E. Frye, EOS
FDA (HFR-CE450)
6751 Steger Drive
Cincinnati, OH 45237

513-679-2700 x149
513-679-2772 (fax)

jfrye@ora.fda.gov

For States: IA, MO, AR, NE, KS, OK, TX, WY, CO, NM, UT

SW Region, EOS
FDA (HFR-SW19)
4040 N. Central Expressway, Suite 900
Dallas, TX 75204

214-253-4930
214-253-4960 (fax)

For States: MT, ID, OR, WA, AK

Suzie Kent, EOS
FDA (HFR-PA3505)
304 North 8th Street, Suite 147
Boise, ID 83702

208-334-1054
208-334-1053 (fax)

skent@ora.fda.gov

For States: AZ, Southern California

Frank Eng, EOS
FDA (HFR-PA1530)
96 N. Third Street, Room 325
San Jose, CA 95112

408-291-7548 x15
408-291-7228 (fax)

feng@ora.fda.gov

For States: Northern CA, NV, HI

Gary Zaharek, EOS
FDA (HFR-PA1530)

408-291-7548 x12
408-291-7228 (fax)

96 N. Third Street
San Jose, CA 95112

gzaharek@ora.fda.gov

Reserve EOS - NE Region

Emir Galevi
FDA/WEAC (HFR-NE480)
109 Holton Street
Winchester, MA 01890

781-729-5700 x 724
781-729-3593 (fax)

egalevi@ora.fda.gov